Tools Required:

 3mm hex key
 Dimensions

 Phillips head screw driver medium
 A: 9-3/8"

 B: 9-3/8"
 B: 9-3/8"

 C: 3"
 C: 3"

Notice to Installer for 33 602:

- 1. BEGA luminaires may be damaged if connected to conduit systems containing water- Article 300-5G of National Electric Code requires that "Conduits or raceways through which moisture may contact energized live parts shall be sealed or plugged at either or both ends".
- 2. Mounts directly to wall or ceiling OVER standard recessed 4" wiring box (by others).
- 3. In conformance with U.L. Standards 1598, a silicone-based sealant MUST be used between the mounting plate edge and supporting wall.
- 4. LEDs are high-quality electronic components! Please avoid touching the light output opening of the LED directly during installation.

33 602 - installation:

- 1. Remove luminaire top with glass with gasket from the luminaire base.
- 2. Feed luminaire wires through luminaire base.
- 3. Make supply wiring and luminaire wiring connections in the octagonal wiring box: MAIN VOLTAGE SUPPLY WIRE TO BLACK LUMINAIRE WIRE NEUTRAL (COMMON) SUPPLY WIRE TO WHITE LUMINAIRE WIRE GREEN GROUND WIRE TO GREEN LUMINAIRE WIRE Dimming (if applicable):

DIMMING CONTROL WIRE (+) TO POSITIVE DRIVER DIM CONTROL WIRE DIMMING CONTROL WIRE (-) TO NEGATIVE DRIVER DIM CONTROL WIRE

- 4. Place a small bead of silicone around the back side of the luminaire base that will come in contact with the finished surface (exterior applications only). Secure lumianire base to ceiling or wall surface using hardware by others (minimum thread size 8-32).
- 5. Tighten screws to secure luminaire top with luminaire base.

Relamping/Maintenance No relamping required.	Accessories Please refer to the appropriate accessory installation sheet for further instruction when applicable.	Replacement Parts Description	Part No
		Lens Lens Gasket	11316411 831575
Lamp: 11.5W LED		LED Driver (120-277V) LED Module (3000K) LED Module (4000K)	75983-02 LED-0841/930 LED-0841/940

Product Safety Warnings:

THIS PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH THE APPLICABLE INSTALLATION CODE BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT AND THE HAZARDS INVOLVED. SUITABLE FOR WET LOCATIONS. MIN 90°C SUPPLY CONDUCTORS.

CE PRODUIT DOIT ÊTRE INSTALLÉ SELON LE CODE D'INSTALLATION PERTINENT, PAR UNE PERSONNE QUI CONNAÎT BIEN LE PRODUIT ET SON FONCTIONNEMENT AINSI QUE LES RISQUES INHÉRENTS. CONVIENT AUX EMPLACEMENTS MOUILLÉS. LES FILS D'ALIMENTATION 90°C MIN.