
### Tools Required:

Flat head screw driver medium Phillips head screw driver medium



<u>Dimensions</u>

14-1/8"

**B**: 4-3/4 "

**OAL**: 79"



Weight: 9.26 lbs.

#### Notice to Installer for 50 352:

- 1. See page 2 for specific product safety warnings.
- Select the desired trim ring or housing material finish by using appropriate code number as suffix.

50 352.2 - Velvet white - matte aluminum

50 352.4 - Velvet white - matte brass

50 352.6 - Velvet white - matte copper

- 3. Mounts directly to standard recessed 4" octagonal wiring box (by others).
- LEDs are high-quality electronic components! Please avoid touching the light output opening of the LED directly during installation.

#### 50 352 - installation:

- Undo set screw on canopy cover and lower canopy cover from canopy baseplate.
- 2. Feed driver wires through canopy baseplate.
- Make supply wiring and driver wiring connections inside the wiring box (by others):

MAIN VOLTAGE SUPPLY WIRE TO BLACK LUMINAIRE WIRE NEUTRAL (COMMON) SUPPLY WIRE TO WHITE LUMINAIRE WIRE GREEN GROUND WIRE TO GREEN LUMINAIRE WIRE

Dimming (if applicable):

DIMMING CONTROL WIRE (+) TO POSITIVE DRIVER DIM CONTROL WIRE


DIMMING CONTROL WIRE (-) TO NEGATIVE DRIVER DIM CONTROL WIRE

- Mount canopy baseplate directly to standard recessed 4" octagonal wiring box (by others).
- Move canopy cover up to the ceiling/canopy baseplate and tighten set screw on canopy cover to secure.

# 50 352 - Cable Shortening:


NOTE: Power cable and steel wire can be shortened on the canopy side ONLY

- 1. Remove canopy cover
- Undo two set screws on canopy strain relief and adjust luminaire power cable to desired length.
- Loosen set screw of steel wire clamp and pull steel wire through to desired length.
- 4. Fix steel wire by tightening set screw. Secure power cable by re-tightening two set screws on canopy strain relief



Canopy Strain Relief

Figure 2: Cable / Wire Shortening (Generic Image)



## Relamping/Maintenance

No relamping required.

### Accessories

Please refer to the appropriate accessory installation sheet for further instruction when applicable.

# **Replacement Parts**

Description Part No
Diffuser 113123.0

Driver (120-277V) 76125-06 LED Module (3000K) LED-0510/930 LED Module (4000K) LED-0510/930

Lamp: 26.9W LED

Product Safety Warnings:
THIS PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH THE APPLICABLE INSTALLATION CODE BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT AND THE HAZARDS INVOLVED. SUITABLE FOR DAMP LOCATIONS.

MIN 90°C SUPPLY CONDUCTORS.

CE PRODUIT DOIT ÊTRE INSTALLÉ SELON LE CODE D'INSTALLATION PERTINENT, PAR UNE PERSONNE QUI CONNAÎT BIEN LE PRODUIT ET SON FONCTIONNEMENT AINSI QUE LES RISQUES INHÉRENTS. CONVIENT AUX EMPLACEMENTS HUMIDES.

LES FILS D'ALIMENTATION 90°C MIN.