

Tools Required:

3mm hex key



Dimensions

A: 8-5/8 "

B: 9-1/4 "



Protection Class: IP 65

Weight: 15.5 lbs

Notice to Installer for 84 681:

- 1. See page 2 for specific product safety warnings.
- 2. Fixture may be damaged if connected to conduit systems that contain water Article 300-5G of the National Electric Code requires that "Conduits or raceways through which moisture may contact energized live parts shall be sealed or plugged at either or both ends."
- 3. Wet location listing does not imply suitability for exposure to standing water for long periods of time.
- 4. LEDs are high-quality electronic components! Please avoid touching the light output opening of the LED directly during installation.
- 5. Supply wiring connection are made to 5-pin connector in accompanying bollard tube. Refer to bollard tube installation instructions for wiring instructions. (Bollard tube with integrated emergency battery pack uses quick disconnects rather than 5-pin connector).

NOTE: For proper installation, an accompanying bollard tube must be selected with the bollard head.

84 681 installation:

- 1. Install bollard tube per bollard tube installation instructions, including anchorage and supply wiring connections.
- 2. Connect male 5-pin connector from bollard head to female 5-pin connector from bollard tube. Twist ring between connectors clockwise as far as it will go until completely sealed. NOTE: THE CONNECTORS WILL ONLY FASTEN IN ONE ORIENTATION TO ENSURE WIRING CONNECTIONS ARE CORRECT.
- 3. Insert bollard head into bollard tube by aligning pins.
- 4. Secure bollard head by tightening 3mm hex set screw.

Re	lamp	ing/l	∕laiı	ntena	nce
No	relan	nping	re	quired	

Bollard Tube Options

Please refer to bollard head specification sheet for a complete list of compatible bollard tube options.

Description

Replacement Parts

Part No

11321611 Lens 830532.1 Lens gasket

75983-02 Driver (120V-277V) LED Module (3000K) LED-0282/830 LED-0282/840 LED Module (4000K)

15.7W LED Lamp:



Product Safety Warnings:

THIS PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH THE APPLICABLE INSTALLATION CODE BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT AND THE HAZARDS INVOLVED. SUITABLE FOR WET LOCATIONS.

MIN 90°C SUPPLY CONDUCTORS.

CE PRODUIT DOIT ÊTRE INSTALLÉ SELON LE CODE D'INSTALLATION PERTINENT, PAR UNE PERSONNE QUI CONNAÎT BIEN LE PRODUIT ET SON FONCTIONNEMENT AINSI QUE LES RISQUES INHÉRENTS. CONVIENT AUX EMPLACEMENTS MOUILLÉS.

LES FILS D'ALIMENTATION 90°C MIN.